



The chart above indicates the level of phosphate on a daily basis over the past year. Phosphate levels are checked three times each day. The average of the three samples is the amount reported for that day and shown on this chart. From March 13 through March 22, the time that there was construction activity near the phosphate feed line that was damaged, there were 9 instances where the phosphate tested at a level outside for the defined range of 0.33 mg/l & 0.67 mg/l. Seven of these instances the level was within 0.03 mg/l of the minimum required.